



WATER FIRE EXTINGUISHER 9 LTR
FIRE EXTINGUISHER
ACCORDING TO EN 3-7:2004

mod. W10P

TECHNICAL CHARACTERISTICS

TOTAL HEIGHT(H): 700 mm
CYLINDER DIAMETER (D): 195 mm
TOTAL WEIGHT: 14.5 kgs
EXTINGUISHING AGENT: Water
PROPELLANT: Nitrogen or Compressed Air
SIPHON TUBE: Plastic PVC
NOMINAL CHARGE: 9 ltrs
DISCHARGE TIME: 40 sec
JET LENGTH: 6 mt
WORKING PRESSURE: 15 Bar
TEST PRESSURE: 35 Bar
BURST PRSSURE: 65 Bar
TEMPERATURE RANGE: +5 + 60 Deg. C
EQUIPPED WITH METAL WALL BRACKET

CYLINDER

Cylindrical body, welded steel type FEP11 **CE marked**.
Upper and lower domes, pressed steel FEP11. Neck gear
M30X1,5 threaded lead steel made.
Serial number and manufacturing year shown on all
cylinders.
Components assembled by electrical welding with
automatic machine, Internal chemical cleaning.
Deep sandblasted and painted with high resistance
epoxy powder for all climate conditions.

VALVE

Brass made P-CuZn40Pb2 squeeze lever type,
CE marked.
Complete with safety valve spring release at 22-24 Bar,
brass made safety pin with seal. Provided with safety
pressure release device during accidental unscrewing
from cylinder neck gear.

MANOMETER

High precision manometer with internal mechanism fully
made in brass.
Dial with green field for working pressure and red field
for under and overpressure.

DISCHARGE HOSE

Made by reinforced rubber with plaited textile
reinforcement, complete with galvanized brass nozzle
and galvanized brass fitting, automatically clamped.
Work pressure 18 bar, test pressure 36 bar and burst
pressure 54 bar.



WATER NOZZLE

Made of galvanized brass specially designed to have best
results with water.

EXTINGUISHING AGENT

Water is the cheapest and the most effective
extinguishing agent for Class A fires. Water extinguish fire
by cooling the material burning.

HOW TO USE

This fire extinguisher can be used against A class of fire
(small dimensions indoor or outdoors).
Pick-up extinguisher, pull out safety pin, press upper
lever, aim at fire base and sweep with water nozzle.

MAINTENACE

Inspect monthly if the manometer needle is in green
area. Check for obstruction into the nozzle, in the water
nozzle and into the hose. If any, clean them with
compressed air. Even after partial use the fire
extinguisher must be refilled.
Yearly inspection required by competent person.

BULLETIN
GEO 500 REV. 2
PAGE 1 OF 1